



8165 E Kaiser Blvd. Anaheim, CA 92808
www.lightlaboratory.com

Report No: L031905909



Report No: L031905909

Issue Date: 4/5/2019

Report Prepared For: Visual Lighting Technologies
1809 Hur Industrial Blvd, Cedar Park, Texas 78613

Model Number: ELL-7SL-6760-35-AL-OP1-WE1-24-UL

Test: Photometric/Electrical Test

Standards Used: Appropriate part or all test guidelines were used for test performed:

IESNA LM79: 2008 Approved Methods for Electrical and Photometric Measurements of Solid-State Lighting Products

ANSI NEMA ANSLG C78.377: 2008 Specification of the Chromaticity of Solid State Lighting Products

ANSI C82.77:2002: Harmonic Emission Limits-Related Quality Requirements for Lighting Equipment

Description of Sample: Client submitted the sample. Received in working and undamaged condition. No modifications were necessary.

Special Test Condition: Fixture is tested with no special conditions.

Sample Arrival Date: 3/28/19

Date of Tests: 3/29/19 - 4/5/19

Seasoning of Sample: No seasoning was performed in accordance with IESNA LM-79.

Equipment List

Equipment Used	Model No	Stock No	Calibration Due Date
Chroma Programmable AC Source	61604	PS-AC02	--
Yokogawa Digital Power Meter	WT210	MT-EL06-S4	1/9/21
BK PRECISION	1747	PS-DC04	1/10/21
Fluke Digital Thermometer	52K/J	MT-TP05	1/10/21
LLI Type C Goniophotometer System	RMG-C-MKII	CD-LL04-GC	--
LLI 2M Sphere	2MR97	CD-SN03-S2	--
LLI Spectroradiometer	SPR-3000	MT-SC01-S2	Before Use

General Information

Manufacturer:	Visual Lighting Technologies
Model Number:	ELL-7SL-6760-35-AL-OP1-WE1-24-UL
Driver Model Number:	N/A

Photometric & Electrical Test Results

Total Lumens:	1107.45
Efficacy:	85.57
Input Voltage (VDC):	24.00
Input Current (Amp):	0.5393
Input Power (W):	12.94
Input Power Factor:	1.0000
Current ATHD (%):	N/A

Test Condition

Ambient Temperature (°C):	25.0
Stabilization Time (Hours):	0:30
Total Operating Time (Hours):	1:20




FIG. 1 LUMINAIRE



8165 E Kaiser Blvd. Anaheim, CA 92808
www.lightlaboratory.com

Report No: L031905909



Test Methods

Photometric Measurements - Goniophotometer

A Custom Light Laboratory Type C Rotating Mirror Goniophotometer was used to measure candelas(intensity) at each angle of distribution as defined by IESNA for the appropriate fixture type.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Spectral Measurements - Integrating Sphere

A Sensing Spectroradiometer SPR-3000, in conjunction with Light Laboratory 2 meter integrating sphere was used to measure chromaticity coordinates, correlated color temperature(CCT) and the color rendering index(CRI) for each sample.

Ambient temperature is set to 25°C and is measured from the center of the fixture, within 1ft from the outside of the fixture. Temperature is maintained at 25°C throughout the testing process and the sample is stabilized for at least 30mins and longer as necessary for the sample to achieve stabilization.

Electrical measurements are measured using the listed equipment.

Disclaimers:

This report must not be used by the customer to claim product certification, approval or endorsement by NVLAP, NIST or any agency of Federal Government.

Report Prepared by : Keyur Patel

Test Report Reviewed by:

Steve Kang
Quality Assurance

**Attached are photometric data reports. Total number of pages: 8*



8165 E. Kaiser Blvd. Anaheim, CA 92808
www.lightlaboratory.com

Photometric Test Report

IES INDOOR REPORT

PHOTOMETRIC FILENAME : L031905909.IES

DESCRIPTION INFORMATION (From Photometric File)

IESNA:LM-63-2002
[TEST] L031905909
[TESTLAB] LIGHT LABORATORY, INC. (www.lightlaboratory.com)
[ISSUEDATE] 4/5/2019
[MANUFAC] Visual Lighting Technologies
[LUMCAT] ELL-7SL-6760-35-AL-OP1-WE1-24-UL
[LUMINAIRE] 7SL Small Square (IP54) Extrusion incl. Edge to Edge Lensing,, 24v Constant Voltage,
[MORE] 875 lm/ft, 6.5 w/ft, 83 CRI, 23.98" (609mm) Fixture Length, Total Wattage of 12.8, 3500°K
[MORE] Silver Anodized Finish, Opal 1 Frosted Lens
[BALLASTCAT] N/A
[OTHER] INDICATING THE CANDELA VALUES ARE ABSOLUTE AND
[MORE] SHOULD NOT BE FACTORED FOR DIFFERENT LAMP RATINGS.
[POWER SUPPLY] 24VDC CONSTANT VOLTAGE SOURCE
[INPUT] 24VDC, 12.94W
[TEST PROCEDURE] IESNA:LM-79-08

CHARACTERISTICS

Lumens Per Lamp	N.A. (absolute)
Total Lamp Lumens	N.A. (absolute)
Luminaire Lumens	1107
Total Luminaire Efficiency	N.A.
Luminaire Efficacy Rating (LER)	86
Total Luminaire Watts	12.94
Ballast Factor	1.00
CIE Type	Direct
Spacing Criterion (0-180)	1.06
Spacing Criterion (90-270)	1.18
Spacing Criterion (Diagonal)	1.20
Basic Luminous Shape	Rectangular
Luminous Length (0-180)	0.03 ft
Luminous Width (90-270)	1.99 ft
Luminous Height	0.00 ft

LUMINANCE DATA (cd/sq.m)

Angle In Degrees	Average 0-Deg	Average 45-Deg	Average 90-Deg
45	55713	62779	70317
55	46068	52993	60125
65	38267	44519	50627
75	33080	38299	42997
85	34990	36375	39145

IES INDOOR REPORT
PHOTOMETRIC FILENAME : L031905909.IES

CANDELA TABULATION

	0	5	10	15	20	25	30	35	40	45
0	515.86	515.86	515.86	515.86	515.86	515.86	515.86	515.86	515.86	515.86
5	511.50	511.54	511.45	511.58	511.66	511.75	511.96	512.12	512.25	512.38
10	496.16	496.24	496.49	496.70	497.08	497.54	498.13	498.71	499.38	500.05
15	470.59	470.80	471.26	471.76	472.64	473.69	474.91	476.25	477.71	479.14
20	436.14	436.35	436.98	437.94	439.49	441.21	443.26	445.61	448.08	450.35
25	394.98	395.27	396.24	397.58	399.67	402.19	405.00	408.35	411.83	415.27
30	350.22	350.59	351.68	353.49	355.92	359.02	362.50	366.56	370.96	375.36
35	304.78	305.20	306.38	308.35	311.07	314.55	318.45	323.02	327.88	332.82
40	260.36	260.78	261.95	263.88	266.69	270.25	274.23	278.93	284.00	289.15
45	218.70	219.07	220.21	222.13	224.77	228.13	231.98	236.47	241.33	246.44
50	180.73	181.02	182.07	183.78	186.09	189.28	192.80	196.86	201.26	205.91
55	146.69	147.03	147.91	149.46	151.60	154.24	157.30	160.90	164.80	168.74
60	116.35	116.68	117.40	118.70	120.41	122.68	125.28	128.21	131.44	134.83
65	89.78	90.03	90.70	91.66	93.00	94.76	96.78	99.25	101.76	104.45
70	67.65	67.69	68.19	68.95	69.99	71.25	72.84	74.56	76.57	78.46
75	47.53	47.74	48.03	48.58	49.25	50.17	51.18	52.47	53.69	55.03
80	30.43	30.51	30.64	30.93	31.39	31.90	32.57	33.28	33.99	34.75
85	16.93	16.89	16.93	17.06	17.06	17.14	17.27	17.39	17.52	17.60
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

Vert. Angles **Horizontal Angles**

	50	55	60	65	70	75	80	85	90
0	515.86	515.86	515.86	515.86	515.86	515.86	515.86	515.86	515.86
5	512.42	512.58	512.75	512.88	512.96	513.05	513.09	513.09	513.09
10	500.72	501.31	501.90	502.48	502.90	503.28	503.57	503.83	503.70
15	480.65	482.03	483.33	484.63	485.64	486.43	487.02	487.44	487.52
20	452.99	455.38	457.64	459.69	461.41	462.84	463.80	464.43	464.64
25	418.91	422.35	425.62	428.47	430.94	432.91	434.25	435.13	435.38
30	379.98	384.21	388.32	391.92	394.98	397.58	399.42	400.43	400.76
35	338.02	342.84	347.45	351.52	355.04	358.01	360.03	361.28	361.62
40	294.60	299.76	304.70	309.10	312.87	315.81	317.99	319.24	319.79
45	251.68	256.71	261.49	265.76	269.41	272.39	274.44	275.61	276.03
50	210.82	215.34	219.75	223.77	227.04	229.64	231.48	232.53	232.86
55	172.72	176.62	180.39	183.83	186.59	188.81	190.41	191.25	191.45
60	138.27	141.58	144.60	147.41	149.63	151.34	152.64	153.31	153.40
65	107.09	109.68	112.07	114.13	115.80	117.19	118.15	118.65	118.78
70	80.43	82.32	84.03	85.54	86.59	87.39	88.06	88.43	88.77
75	56.41	57.59	58.68	59.64	60.40	60.94	61.36	61.65	61.78
80	35.54	36.21	36.84	37.30	37.72	38.06	38.22	38.48	38.56
85	17.73	17.90	18.06	18.19	18.40	18.53	18.69	18.82	18.94
90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

IES INDOOR REPORT
PHOTOMETRIC FILENAME : L031905909.IES

ZONAL LUMEN SUMMARY

Zone	Lumens	%Lamp	%Fixt
0-20	183.20	N.A.	16.50
0-30	374.07	N.A.	33.80
0-40	582.30	N.A.	52.60
0-60	925.17	N.A.	83.50
0-80	1088.37	N.A.	98.30
0-90	1107.45	N.A.	100.00
10-90	1058.94	N.A.	95.60
20-40	399.10	N.A.	36.00
20-50	590.09	N.A.	53.30
40-70	447.33	N.A.	40.40
60-80	163.20	N.A.	14.70
70-80	58.74	N.A.	5.30
80-90	19.07	N.A.	1.70
90-110	0.00	N.A.	0.00
90-120	0.00	N.A.	0.00
90-130	0.00	N.A.	0.00
90-150	0.00	N.A.	0.00
90-180	0.00	N.A.	0.00
110-180	0.00	N.A.	0.00
0-180	1107.45	N.A.	100.00

Total Luminaire Efficiency = N.A. %

ZONAL LUMEN SUMMARY

Zone	Lumens
0-10	48.51
10-20	134.69
20-30	190.87
30-40	208.23
40-50	190.98
50-60	151.89
60-70	104.46
70-80	58.74
80-90	19.07
90-100	0.00
100-110	0.00
110-120	0.00
120-130	0.00
130-140	0.00
140-150	0.00
150-160	0.00
160-170	0.00
170-180	0.00


IES INDOOR REPORT
PHOTOMETRIC FILENAME : L031905909.IES

COEFFICIENTS OF UTILIZATION - ZONAL CAVITY METHOD

Effective Floor Cavity Reflectance 0.20

RC	80				70				50			30			10			0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	110	105	101	98	107	103	99	96	99	96	93	95	92	90	91	89	88	85
2	100	93	86	81	98	91	85	80	87	83	78	84	80	77	81	78	75	73
3	92	82	75	69	90	81	74	68	78	72	67	75	70	66	73	68	65	63
4	85	74	66	59	83	72	65	59	70	63	58	68	62	57	66	61	56	54
5	79	66	58	52	77	65	57	51	63	56	51	61	55	50	60	54	50	48
6	73	60	52	46	71	59	51	46	58	50	45	56	50	45	54	49	44	42
7	68	55	47	41	66	54	46	41	53	46	40	51	45	40	50	44	40	38
8	63	51	42	37	62	50	42	37	49	42	36	47	41	36	46	40	36	34
9	59	47	39	33	58	46	39	33	45	38	33	44	38	33	43	37	33	31
10	56	43	36	31	55	43	35	30	42	35	30	41	35	30	40	34	30	28

POLAR GRAPH



Maximum Candela = 515.86 Located At Horizontal Angle = 0, Vertical Angle = 0
1 - Vertical Plane Through Horizontal Angles (0 - 180) (Through Max. Cd.)
2 - Vertical Plane Through Horizontal Angles (90 - 270)
3 - Horizontal Cone Through Vertical Angle (0) (Through Max. Cd.)